

KOZLODUY NPP EAD

Bulgaria, tel. +359 973 7 35 30, fax +359 973 7 60 27

**TO WHOM
IT MAY CONCERN**

CLARIFICATIONS

Re: Call for market consultation on the grounds of Article 44 of the PPA for the submission of indicative proposals for Modernisation of fuel handling machines 5,6PL00E01, type MIIC-B-1000-3M-Y 4.2.

Dear Sirs/Madams,

Referring to the call for market consultation for the submission of indicative proposals for **Modernisation of fuel handling machines 5,6PL00E01, type MIIC-B-1000-3M-Y 4.2**, the following clarifications are provided:

Questions:

Question No. 1 Sealed cable penetrations. Do any sets for connecting cables to sealed penetrations have to be delivered within the scope of this procurement?

Answer to question No. 1: The sets for connecting the cables to sealed penetrations have to be delivered.

Question No. 2 What is the cable length from the sealed penetrations to the KESZ cabinet?

Answer to question No. 2: The approximate cable length from the sealed penetrations to the KESZ cabinet is about 200 metres. When the unit is shut down for an outage, the exact cable lengths will be measured.